



District Level Laboratory PHED, Sasaram, Rohtas  
Old G.T.Road, Near Railway Station, Sasaram, (Rohtas)  
eephedrohtas@gmail.com Ph.No :- 8544428572/8544428639



बिहार सरकार

TC-14408

## TEST REPORT

Name & Address Of the Customer:-  <b>Oxford Convent School Nokha Nawadiah Hathani, Mor</b>	Report No.	: SRM/W/2026-27/R/ 11
	Date	: 26/05/2026
	Sample No.	: SRM/W/26-27/11
	Sample Description	: Drinking Water
	Sample Mark/ Location	: <b>Oxford Convent School</b>
	Sample Collected On	: 20/05/2026
	Sampling Plan & Method	: IS 3025(Part 1)
	Date of Performance (s)	: 20/05/2026 to 26/05/2026
	Ref No. Date	:

### Analysis Result

Sl. No.	Test Parameter	Test Method	IS 10500:2012Amd. 1 & 2		Result
			Acceptable Limit	Permissible Limit	
1	pH	IS 3025(Part 11) : 20222	6.5-8.5	NR	7.39
2	Turbidity	IS 3025(Part 10) : 2023	1 NTU	5 NTU	1
3	TDS	IS 3025(Part 16) : 2023	500 mg/ L	2000 mg/ L	320
4	Total Hardness	IS 3025(Part 21) : 2019	200 mg/ L	600 mg/ L	220
5	Calcium	IS 3025(Part 40) : 2023	75 mg / L	200 mg/L	66
6	Magnesium	APHA 24rd Edition -3500-Mg Method B (Calculation Method) : 2023	30 mg / L	100 mg/ L	36.2
7	Iron	APHA 23rd Edition -3500-Fe Method B (Phenanthroline Method) : 2023	1 mg/ L	NR	0.1
8	Chloride	IS 3025(Part 32) : 2019	250 mg/ L	1000 mg / L	52
9	Total Alkalinity	IS 3025(Part 23) : 2023	200 mg / L	600 mg / L	190
10	Fluoride	APHA 23rd Edition -4500-F Method C (Electrode Method) : 2023	1 mg / L	1.5 mg / l	0.632
11	Colour	IS 3025 (Part 4) : 2021	5	15	<1
12	Odour	IS 3025 (Part 5) : 2022	Agreeable	Agreeable	Agreeable
13	Taste	IS 3025 (Part 8) : 2023	Agreeable	Agreeable	Agreeable

Reviewed

Chemist

D.L.L Sasaram, Rohtas

*R. Kumar*  
26/05/2026

Authorized

Technical Manager

D.L.L Sasaram, Rohtas

*S. Singh*  
26.05.2026

#### Disclaimer:

- The result relates only to the items(S) tested
- The report shall not be reproduced except in full, without approval of the laboratory
- The reserved part of water samples (s) shall be retained for 15Days from the date of issue of the test Report.
- The laboratory is responsible for all the information given in the report.