

Escape Route Inspection St Mary's Hospital Drogheda

Date:										
	AM :Time			PM: Time			NIGHT :Time			Comments
	Yes	No	Sig	Yes	No	Sig	Yes	No	Sig	
All escape routes are kept un-obstructed and immediately										
available for use										
Escape routes are clearly indicated, signposted and adequately										
illuminated by the main and emergency lighting systems										
Exit doors are capable of being readily opened at all times										
Doors and gates across escape routes are secured in a manner that										
they can be easily and immediately opened by persons on the										
premises										
Curtains, drapes or hangings are not placed across or along an										
escape route in a manner which would impede or obstruct escape										
Mirrors are not placed across or along an escape route or adjacent										
to an exit in such a way as to confuse the direction of escape										
Floor coverings, rugs and mats are fixed or laid so that people										
will not slip or trip on them during an evacuation, and they are not										
used to prop open doors										
Fire resisting door sets along escape routes are kept closed at all										
times, unless where they are held open with electro-magnetic										
devices linked to the fire alarm system during the day and closed										
at night										
External areas at or near exits are kept free of vehicles, portable										
cabins, excavations and or other obstructions, so as to allow										
unimpeded escape to a place of safety										
Doors, gates or traffic do not block escape from a concourse or										
yard to a place of safety in the open air										