

Escape Route Inspection The Village Residence

| Date: | | | | | | | | | | |
|---|----------|----|-----|----------|----|-----|--------------|----|-----|----------|
| | AM :Time | | | PM: Time | | | NIGHT : Time | | | Comments |
| | Yes | No | Sig | Yes | No | Sig | Yes | No | Sig | |
| All escape routes are kept un-obstructed and immediately available for use | | | | | | | | | | |
| Escape routes are clearly indicated, signposted and adequately illuminated by the main and emergency lighting systems | | | | | | | | | | |
| Exit doors are capable of being readily opened at all times | | | | | | | | | | |
| Doors and gates across escape routes are secured in a manner that they can be easily and immediately opened by persons on the premises | | | | | | | | | | |
| Curtains, drapes or hangings are not placed across or along an escape route in a manner which would impede or obstruct escape | | | | | | | | | | |
| Mirrors are not placed across or along an escape route or adjacent to an exit in such a way as to confuse the direction of escape | | | | | | | | | | |
| Floor coverings, rugs and mats are fixed or laid so that people will not slip or trip on them during an evacuation, and they are not used to prop open doors | | | | | | | | | | |
| Fire resisting door sets along escape routes are kept closed at all times, unless where they are held open with electro-magnetic devices linked to the fire alarm system during the day and closed at night | | | | | | | | | | |
| External areas at or near exits are kept free of vehicles, portable cabins, excavations and or other obstructions, so as to allow unimpeded escape to a place of safety | | | | | | | | | | |
| Doors, gates or traffic do not block escape from a concourse or | | | | | | | | | | |