

## **REPORT: ST MARYS DROGHEDA**

### **GRADE 1**

ITEM	STATUS	CONCLUSION
Replace RCBO's in the following SDB's: <ul style="list-style-type: none"><li>DB2 3 no. RCBO's</li><li>Kitchen DB 6 no. RCBO's</li><li>DB1 1 no. RCBO</li></ul>	Completed Completed Completed	

### **GRADE 2**

Bond Sinks/metal work/pipes 23 no. in the following areas: <ul style="list-style-type: none"><li>Room 28</li><li>Room 26</li><li>Room 33</li><li>Room 22</li><li>Room 31</li><li>Kitchen</li><li>Room 6</li><li>Boiler House</li><li>Room 53</li></ul>	Not Completed  Completed Completed Not Completed  Completed Completed Not Completed  Completed Not Completed	No local exposed outlet so no requirement to bond       No local exposed outlet so no requirement to bond      No local exposed outlet so no requirement to bond    Plastic pipes feeding sink so no requirements to bond
Replace & move IP TP isolator Room 33	Completed	
Upgrade panel wire in kitchen DB	Completed	
Replace broken sockets (x2) room 28	Completed	
Install extra MC twin socket beside existing in kitchen	Not Completed	Could not find
Replace broker IP isolator room 27	Completed	
Install new IP TP isolator	Completed	
Move existing isolator to more accessible point in kitchen	Completed	
Blank off existing 5A's sockets (no RCD protection) allow 15 no.	Completed	
Replace existing brass 2g sockets in room 23 2 no.	Completed	

Replace trailing leads with 3nr. 2g sockets in room 53	Not Completed	Could not find
Replace 2nr. MC 1g sockets in room 53	Not Completed	Could not find

### **GRADE 3**

Label the following SDB's:  <ul style="list-style-type: none"> <li>• DB2</li> <li>• DB1</li> </ul>	Completed Completed	
Replace broken 1g switch rooms 27,30	Completed	
Replace broken fluorescent lights (x2) room 27	Completed	
Refix light fitting & mini trunking room 31	Completed	
Install fused spur for fan controller kitchen	Completed	
Refix lights in corridor	Completed	
Install junction box on cables in boiler house	Completed	
Refix existing junction box onto wall in boiler house	Completed	

### **GRADE 4**

Install phase colour warning stickers on all SDB's	Completed	
Install RCD stickers on all SDB's	Completed	

#### **NOTE:**

**BONDING SINK – See section 'Equipotential bonding' in the NSAI regulations I.S. 10101:2020 Edition 5.0**