



## Risk Assessment Form

<b>Division: Social care Midlands Louth Meath</b>		<b>Source of Risk: Risk Assessment on Electricity Risk Assessment</b> Electrical Items, Plugs, Cables, Overloaded Sockets		
<b>HG/CHO/NAS/Function: CHO 8 Older People services</b>		<b>Primary Impact Category:</b> Harm to Person		
<b>Hospital Site/Service: Drogheda Services for Older People</b>		<b>Risk Type: <u>Operational</u></b>		
<b>Dept/Service Site: The Village Residence</b>		<b>Name of Risk Owner (BLOCKS): Seamus Mc Caul</b>		
<b>Date of Assessment: 21/09/2023</b>		<b>Signature of Risk Owner: As Above</b>		
<b>Unique ID No: RA005</b>		<b>Risk Co-Ordinator: Andrea Doorly</b>		
		<b>*Risk Assessor (s): Seamus Mc Caul/ Leena Varghese, Jolly Varghese</b>		
<b>**HAZARD &amp; RISK DESCRIPTION</b>	<b>EXISTING CONTROL MEASURES</b>	<b>ADDITIONAL CONTROLS REQUIRED</b>	<b>ACTION OWNER (i.e. the Person responsible for the action)</b>	<b>DUE DATE</b>
<b>Hazard:</b> Electricity <b>Risk:</b> Electrocution/ Electric Shock, Electrical Burns, Fire	<ul style="list-style-type: none"><li>• All electrical Installations to be completed by a competent and qualified electrician. Staff to have access to technical services.</li><li>• Adequate power points to be available, no overloading of Sockets.</li><li>• Sockets are to be switched off when not in use</li><li>• Mobile Phone Chargers are to be unplugged when not in use.</li><li>• Cables to be in good state of repair. User to visually inspect outlet and equipment before use.</li><li>• Staff are advised to spot and report (to their line</li></ul>		All staff Maintenance staff ADON DON	Sept 2024



	<p>supervisor ) any defective plugs, discoloured sockets or damaged cable/ equipment.</p> <ul style="list-style-type: none"><li>Defective equipment is to be taken out of use immediately, labelled as not for use, and removed completely for safe disposal/repair as soon as possible.</li><li>Equipment which has been deemed defective is to be safely and promptly replaced.</li><li>Contact Line Manager if you have concerns regarding the safety of an electrical item.</li></ul>				
INITIAL RISK			Risk Status		
Likelihood	Impact	Initial Risk Rating	Open	Monitor	Closed
2	2	4		✓	

\*Risk Assessor to be recorded for OSH risks only.

\*\*Where the risk being assessed relates to an OSH risk please ensure that the HAZARD and associated risk are recorded on the form. All other risk assessments require a risk description only.