

**मुख्य अग्निशमन अधिकारी**  
**OFFICE OF THE CHIEF FIRE OFFICER**  
**अण्डमान तथा निकोबार द्वीप समूह**  
**Andaman and Nicobar Islands**

Clearance Number : **FS/FCC/2024/1495**

Port Blair dated **11/12/2024**

**FIRE CLEARANCE CERTIFICATE**

This is to certify that the **BVB MONDAL PUBLIC SECONDARY SCHOOL** situated at **MADHUPUR, DIGLIPUR, NORTH AND MILLDE ANDAMAN-744202 ,DIGLIPUR ,DIGLIPUR** bearing Survey No. **115/2** have complied with the fire prevention and fire safety requirements in accordance with NBC guidelines and verified by Fire Brigade Officer on **05/11/2024** and the school is safe from fire safety point of view for a period of one (1) year from the date of issue of this FCC, subject to compliance of specific conditions as appended:-

Note:- Conditions for the validity of Fire Clearance Certificate (FCC)

1. Building stability and satisfactory electrical installation to be ascertained from concerned agency.
2. FCC shall stand null and void if there is any violation in the existing firefighting arrangements.
3. FCC may not be treated in any case for regularization of unauthorized construction, if any or violation in the building plan.
4. All fire safety arrangements provided therein shall be maintained in good working conditions at all time and all staff members shall be well acquainted to operate all fire safety equipments.
5. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
6. Trained firefighting staff should be available in the school during school hours.
7. Any deviation with reference to construction etc. shall be verified by the concerned building sanctioning authority.

8. Means of escape shall be kept unobstructed/unlocked for unhindered evacuation in case of any emergency
9. Occupant load in class room should not be more than 4 m<sup>2</sup> per students.
10. No combustible material should be used for construction of school building.

Copy to : -

- 1) Deputy Commissioner, North & Middle Andaman District for information.
- 2) The Assistant Commissioner, Diglipur for information.
- 3) STO, F&ES Diglipur for information and necessary action.



**Inspector Fire Brigade (Mayabunder)**  
Andaman and Nicobar Islands

**To**

SUSHIL MONDAL  
MADHUPUR, DIGLIPUR, NORTH AND MIDDLE ANDAMAN-744202  
DIGLIPUR  
DIGLIPUR  
NORTH & MIDDLE ANDAMAN - 744202

