

सहायक अभियंता का कार्यालय
उप मंडल. नं.- II
निर्माण मंडल, अ.लो.नि.वि.
डिग्लीपुर, उ. एवं म. अण्डमान



OFFICE OF THE ASSISTANT ENGINEER

SUB DIVISION NO-II
CONSTRUCTION DIVISION, A.P.W.D.
DIGLIPUR, N & M ANDAMANS

No. 2-22/SD-II/CD/APWD/2025/691

Diglipur, dated 17 Nov., 2025

To

The Principal,
BVBMondal Public School,
Madhupur, Diglipur
North Andaman

Sub: Testing of potable water collected from BVB Mondal Public School-reg.

Sir,

With reference to your letter No. BVBMPPSS/MP/DP/2025-26 dated 01.11.2025 on the subject cited above, the test results of the potable water sample collected from BVB Mondal Public Secondary School, Madhupur, Diglipur are enclosed herewith as an annexure for further necessary action.

Encl:A/A

Yours faithfully,

Assistant Engineer-II
CD, APWD, Diglipur

Copy to:


1. The Executive Engineer, CD, APWD, Diglipur for kind information.


Assistant Engineer-II
CD, APWD, Diglipur

**TEST RESULTS FOR WATER SAMPLE AT
BVB MONDAL PUBLIC SECONDARY SCHOOL**

Sample ID:

Sl.no	Details		
1	Name of District	North and Middle Andaman	
2	Name of Block	Diglipur	
3	Name of Panchayat	Madhupur	
4	Name of Village/Habitation	Madhupur	
5	Location and address of sampling point	BVB MONDAL PUBLIC SECONDARY SCHOOL	
6	Type of scheme	NA	
7	Collected by (Name,designation and office)	Smti Mallika (Junior Engineer) Madhupur Section ,SD -II CD, APWD,Diglipur	
8	Date of Collection	10.11.2025	
S.no	Water quality parameters	AS Per BIS 10500:2012 Acceptable Limit	Test Result Value (mg/L)
1	Colour	5	5
2	Odour	Aggreable	Aggreable
3	Turbidity	1	0.0 NTU
4	pH	6.5-8.5	6.50
5	Taste	Aggreable	Aggreable
5	Alkanity	200 mg/L	20 mg/L
6	Hardness	200 mg/L	0.0 mg/L
7	Chloride	250 mg/L	50 mg/L
15	Total dissolved solids	500 mg/L	84 mg/L
REPORT - The water is found to be portable .			


Junior Engineer
Madhupur Section
Sub Division-II


Assistant Engineer
Sub Division-II
CD, APWD, Diglipur