



HEAD OFFICE
Uttarakhand Pollution Control Board
"Gaura Devi Paryavaran Bhawan"
46B, IT Park, Sahasradhara Road, Dehra Dun
E-mail : msukpcb@yahoo.com, Phone No.-0135-2607092

UKPCB/HO/Con(R)/B-213 /2024/1828

Date : 26/3/24
REGD. POST

To,

✓ M/s Bharat Environmental Solutions
 Khasra No. 923 to 1002, Village Kodarna
 Tehsil-Narendra Nagar
 Distt- Tehri Garhwal

Consolidated Consent to Operate and Authorisation hereinafter referred to as the CCA (Consolidated Consent & authorization) (Renewal) under Section-25 of the "Water (Prevention & Control of Pollution) Act, 1974" and under Section-21 of the "Air (Prevention & Control of Pollution) Act, 1981" and Authorization under "Rule-6(2)" of the "Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016" notified under "Environment (Protection) Act, 1986" as applicable (to be referred hereinafter as Water Act, Air Act and H&O W Rules respectively).

CAF ID -30762
 CCA (Renewal)

Application No. – 5204463
 Date :-09-02-2024

CCA is hereby granted to M/s Bharat Environmental Solutions located at Khasra No. 923 to 1002, Village Kodarna, Tehsil- Narendra Nagar, Distt- Tehri Garhwal subject to the provisions of the Water Act, Air Act and Hazardous and Other Wastes (Management and Transboundary Movement) Rules, 2016 and the orders that may be made further and subject to following terms and conditions :-

- This CCA is granted for the period upto 31.03.2029 and valid for management of following wastes with Capital Investment Net Assets Values ₹ 112.0 Lakh :-

S. No.	Last CCA		Present CCA (Renewal)	
	Processing & disposal	Quantity	Processing & disposal	Quantity
1	Bio-Medical Waste	4000 Kg/day	Bio-Medical Waste	4000 Kg/day

- Specific Conditions under Water Act :-

- The daily quantity of effluent discharge (KLD) :-

	Last CCA	Present CCA (Renewal)
Trade Effluent	6.6 (100% Recycle after Treatment)	6.6 (100% Recycle after tertiary level Treatment)
Sewage	0.48	0.48

- Trade Effluent Treatment and Disposal :-** The applicant shall operate Effluent Treatment Plant (10 KLD capacity) consisting of primary/secondary and tertiary treatment as is required with reference to influent quantity and quality.

In case of stoppage of functioning of ETP, production has to be stopped immediately and this Board has to be intimated by fax/phone/email with a report in this regard to be dispatched immediately.

- The treated effluent shall be recycled in non-potable uses. Quality of the treated effluent shall meet to the following general and specific standards as prescribed under the Bio-Medical Waste Management Rules, 2016 (as amended) as applicable to the unit from amended time to time:-

1	pH	Between	6.9-9.0
2	Suspended solids	Not to exceed	100mg/l
3	BOD (3 days 27°C)	Not to exceed	30 mg/l
4	COD	Not to exceed	250 mg/l