


## Fire Safety - Undertaking

### Category of application : Fresh Affiliation Up to Secondary Level

I, Mridul Kumar Nath, Principal In charge of the school ADARSHA VIDYALAYA RANGAPARA do hereby undertake that the school run/ applied under regular category is unable to obtain/ renew Fire Safety Certificate issued from the Fire Safety Department of the State Government/ Competent Government Authority eg. Municipal Corporation etc. of the concerned area till date of application. The school was last inspected for the safety on: 30/06/2023.

I assure that before starting of the regular school/ commencement of session the above safety certificate will be obtained and submitted. In the meanwhile whole responsibility of the safety and security of staff and students will be on undersigned. Therefore, being a regular category school it may be provisionally allowed.

Principal Sign:



Principal Name: MRIDUL K. NATH.

School Address: 1. B Moirajuli Phulaguri Rangapara.

Date: 26-03-24


Place: Sonitpur, Tezpur

Seal:

Principal  
Adarsh Vidyalaya, Rangapara  
District- Sonitpur, Assam

Inspected Adarsha vidyalaya building and suggest  
install fire safety equipment as follows:-

- ① Common room - ABC extinguisher - 1 Nos.
- ② Electric panel Board - CO<sub>2</sub> extinguisher - 1 Nos.
- ③ Office room - ABC extinguisher - 1 Nos.
- ④ Library room - ABC extinguisher - 1 Nos.
- ⑤ Lower class room - ABC extinguisher - 2 Nos.
- ⑥ Computer Laboratory - CO<sub>2</sub> extinguisher - 1 Nos.
- ⑦ Science Laboratory (1+2) - CO<sub>2</sub> extinguisher - 2 Nos.  
ABC extinguisher - 2 Nos.
- ⑧ Upper class room - ABC extinguisher - 7 Nos.

  
30/6/23  
Station Officer  
Rangapara F&ESS  
Dist. - Sunitpur (Assam)