

ATTESTATION OF CONFORMITY

Issued to: SUNGO Energy Technology (Jiangsu) Co.,Ltd.
Unit 1, First Floor, 179 Suhong Westroad, Industrial Park, Suzhou City, Jiangsu
Province P.R. China

For the product: Photovoltaic Power Optimizer

Trade name: SUNGO

Type/Model: SUNGO-OPT PRO

Ratings: Operation temperature: -40 to 60 °C
Input: Max voltage:70 Vdc, MPPT voltage range: 7-60 Vdc
Max continuous current: 21 A, Max power: 800 W;
Output: Rated voltage: 58 Vdc, Max continuous current: 21 A, Max power: 780 W.

Manufactured by: SUNGO Energy Technology (Jiangsu) Co.,Ltd.
Unit 1, First Floor, 179 Suhong Westroad, Industrial Park, Suzhou City, Jiangsu
Province P.R. China

Requirements: EN 62109-1:2010

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6157787.50

This Attestation implies that the examined types are in accordance with the standards designated under the Low Voltage Directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Arnhem, 27 June 2023

Number: 6157787.01AOC

DEKRA Testing and Certification (Shanghai) Ltd.

Kreny Lin
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

