

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 602

Dated: 22/05/2025

It is certified that an inspection team headed by MR. BALWINDER SINGH

(Name of Officers with designation) from A. En PHED

inspected the FLORADALE PUBLIC SCHOOL, SRI GANGANAGAR

(Name & Address of the school) on 22/05/2025 (date of inspection) and on the basis of

Water Test Report (Attached) bearing no. 170 dated 14/05/2025

of DISTRICT LAB, SRI GANGANAGAR (PHED Lab) certified that the

FLORADALE PUBLIC SCHOOL (Name of school) has safe drinking water

facilities for the students and members of staff of the institution. School is also maintains the

hygienic sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 22/05/2027

Signature with Seal: सहायक अभियन्ता
Name: जय रत्ना अम्बि विभाग
Designation: नगर निगम, श्री गंगानगर
Name & Address of the Office / Department: PHED, SRI GANGANAGAR

To FLORADALE PUBLIC SCHOOL
VIDHA DEEP VIHAR, OPP. RADHA SWAMI DERA

(Name & Address of the Institution)
SURATGARH PADAMPUR BYPASS
SRI GANGANAGAR (RAJ.)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies



Office of the Junior Chemist
Public Health Engineering Department, Rajasthan
District Laboratory, Ganganagar

Report of the Chemical Examination of Water

Sl. No. 1170
14/5/2025

To
Shree Ikhvire Singh,
Floradale Public School, Opp. Radha Swami Dera,
Sri Ganganagar.

Reference No 00, Dated: 12/05/2025

Date of Receipt: 12/05/2025

District : GANGANAGAR

Sample Taker : Your Self

Source	Permissible Value as per B.I.S : 10500/2012		Tap
Location			Near Office Inside School
Other Habitation			
Village/Town			Ganganagar (MCI)
Gram Panchayat	Desirable Limit	Permissible limit in absence of alternate Source	
Date of Collection			12/05/2025
Date of Examination			13/05/2025
Sample No.			205

Note:- All results except pH are in mg/L

pH	6.5 to 8.5	No relaxation	7.5
Turbidity(NTU)	1	5	1
Colour	5	15	Colourless
Odour	Agreeable	Agreeable	Smell less
Temperature	—	—	—
Total Alkalinity	200	600	120
Total Hardness (as CaCO ₃)	200	600	150
Calcium (as Ca)	75	200	20
Magnesium (as Mg)	30	100	24.4
Chloride(as Cl)	250	1000	30
Sulphate(as SO ₄)	200	400	—
Nitrate as(NO ₃)	45	45	2
Fluoride	1.0	1.5	0.27
Total Dissolved Solids	500	2000	300
Iron	1.0	No Relaxation	—
Residual Chlorine	0.2	1.0	0

Note : (1) Samples are not
collected by laboratory.

(2) Report is not valid for
water quality legal purposes.

Remarks : Water is Potable (P)/Unpotable (U)
No.Lab/Tech.(chem)/2025-26/205

Willpreet Kaur

Principal
Floradale Public School
Sri Ganganagar(Raj.)

(प्रभा रसा)

अनिष्ट रसा

जय स्वा. अ. रसा
Junior Chemist
District Laboratory, Ganganagar
Sl. No. 1170

फलोराडेल पब्लिक स्कूल समिति
सचिव