

Dear Sir,

We take the privilege to bring this to your kind notice that Diesel Generating Set emission parameters has been revised by MoEFCC, Govt. of India as per published Gazette CG-DL-E-04112022-240031 dated 3rd Nov 2022.

This is an extension to the DG Set Emission law as per CPCB-IV published by CAQM i.e. Circular A-110018/01/2021-CAQM.

All the DG Sets (Existing and New) should comply CPCB-IV Emission norms by implementing Retrofit Emission Control Device (RECD)

We are glad to inform you that, we have successfully tested an above expectation "Retrofit Emission Control Device - RECD" which has shown 96% pollutant conversion results in the durability and conversion test.

We have RECD devices which can be customised for all brands of DG Sets having varying capacity ranging from 1KVA to 4000 KVA. We intend to further draw your attention towards providing RECD for DG Sets having capacity over 800 KW. These DG Sets are most polluting in terms their Diesel consumption and heavy pollution emission in the environment.

We as a company feel that our focus of these big capacity DG Sets will help speed up the achievement of "Zero emission" goal of our Government. Henceforth we have attached a presentation categorically inclined towards RECD devices for 800 KW and above capacity DG Sets.

Please let us give you more insights by meeting your kind self personally and discussing how to work together in reducing pollution from our environment.

Warm Regards,

Raj Khanna
Director
Dekonix India
raj@dekonixindia.com
+91 9810195391



Actual picture for reference

Solution For “Pollution”

Capacity : 800 KW and above
Diesel Generator Set

M5, 2nd Flr , M-Block Mkt
Greater Kailash – Part 1
New Delhi 110048
+91 9810195391
raj@dekonixindia.com
www.dekonixindia.com

EMISSION STANDARDS FOR DIESEL ENGINES (ENGINE RATING MORE THAN 0.8 MW (800 KW) FOR POWER PLANT, GENERATOR SET APPLICATIONS AND OTHER REQUIREMENTS


Parameter	Area Category	Total engine rating of the plant (includes existing as well as new generator sets)	Generator sets commissioning date		
			Before 1.7.2003	Between 1.7.2003, and 1.7.2005	On or after 1.7.2005
NO _x (as NO ₂), (AT 15% O ₂), dry basis, in ppmv	A	Upto 75 MW	1100	970	710
	B	Upto 150 MW			
	A	More than 75 MW	1100	710	360
	B	More than 150 MW			
NMHC (as C)(at 15% O ₂), mg/Nm ³	Both A and B		150	100	
PM (at 15% O ₂), mg/Nm ³	Diesel Fuels- HSD & LDO	Both A and B	75	75	
			150	100	
CO (at 15% O ₂), mg/Nm ³	Both A and B		150	150	
Sulphur Content in fuel	A		< 2%		
	B		< 4%		
Fuel specification	For A only	Up to 5MW	Only Diesel fuels (HSD, LDO) shall be used.		
Stack height (for generator sets commissioned after 1.7.2003)	Stack height shall be maximum of the following, in meter: (i) $14 Q^{0.3}$, Q= Total SO ₂ emission from the plant in kg/hr. (ii) Minimum 6 m. above the building where generator set is installed. (i) 30 m.				



Emission Parameters: Actual Vs CAQM Vs EO Energy Commitment

EMISSION STANDARDS FOR DIESEL ENGINE S (ENGINE RATING MORE THAN 0.8 MW (800 KW) FOR POWER PLANT, GENERATOR SET APPLICATIONS AND OTHER REQUIREMENTS						As per CAQM Notification F. No. A-110018/01/2021-CAQM	As per CAQM Notification F. No. A-110018/01/2021-CAQM
<i>(Emission Standards for Diesel Engines (Engine Rating more than 0.8 MW (800 KW) were notified by the Environment (Protection) Third Amendment Rules 2002, vide G.S.R. 489 (E), dated 9th July, 2002 at serial no. 96, under the Environment (Protection) Act, 1986.)</i>							
Parameter	Area Category	Total engine rating of the plant (includes existing as well as new generator sets)	Generator sets commissioning date			Direction No - 68 dated 14.09.2022 Direction No - 73 dated 02.06.2023	EO Energy Pvt Limited Committed to Achieve
			Before 1.7.2003	Between 1.7.2003 and 1.7.2005	On or after 1.7.2005		
NOx (as NO ₂) (AT 15% O ₂) , dry basis, in ppmv	A	Upto 75 MW	1100	970	710	650 mg/Nm ³	≤ 650 mg/Nm ³
	B	Upto 150 MW					
	A	More than 75 MW	1100	710	360		
	B	More than 150 MW					
NMHC (as C) (at 15% O ₂), mg/Nm ³	Both A and B		150	100			
PM (at 15% O ₂), mg /Nm ³	Diesel Fuels- HSD & LDO Furnace Oils-LSHS & FO	Both A and B	75	75		50 mg/Nm ³	≤ 25 mg/Nm ³
		Both A and B	150	100			
CO (at 15% O ₂),	Both A and B		150	150		100 mg/Nm ³	≤ 45 mg/Nm ³
Sulphur Content in fuel	A				< 2%		
	B				< 4%		
Fuel specific ation	For A only	Up to 5MW	Only Diesel fuels (HSD, LDO) shall be used.				
Stack height (for generator sets commissioned after 1.7.2003)	Stack height shall be maximum of the following, in meter: (I) 14 Q _{0.1} , Q ₀ = Total SO ₂ emission from the plant in kg / hr. (II) Minimum 6 m, above the building where generator set is installed. (III) 30 m.				Maximum of the following (in mtr) (I) Minimum 6 m above the building where DG set is installed. (II) 30 M.		

Device Configuration (NOx + PM + HC + CO)



Why: EO Energy Private Ltd.

EO Energy Pollution Control Device that is capable of handling loads exceeding 800 kW.

High-Performance Exhaust Gas Filtration System or Pollution Control Device for Diesel Generator Sets of more than 800 KW ratings

Exhaust Polluted Gas Filtration System or Pollution Control Device, designed to reduce harmful emissions from diesel generator sets significantly. Our system utilizes advanced Diesel Particulate Filter (DPF), DOC (Diesel Oxidation Catalyst) and Selective Catalytic Reduction (SCR)

Diesel Oxidation Catalyst Catalytic) and SCR(Selective Catalyst Reduction) technology, providing superior performance compared to traditional methods like water filtration and electrostatic precipitator (ESP).

Key Features and Benefits:

- **Exceptional Black Smoke Purification:** Achieves a purification rate of up to 85-98%, effectively reducing black smoke emissions.
- **Automatic Regeneration:** Our Catalyst Continuously Regenerating Technology (CCRT) ensures efficient and automatic removal of particulate matter (PM), CO, HC, NO, NO₂, NO_x and other harmful gases without additional pollution.
- **Enhanced Diesel Oxidation:** The integrated Diesel Oxidation Catalyst (DOC) promotes chemical oxidation of CO, HC, and SOF portions of diesel particulates.
- SCR is a continuous process that reduces nitrogen oxide (NO_x) emissions from a diesel engine .
- **High-Quality Construction:** Our system features durable materials and precise engineering for long-term reliability.
- **Easy Installation:** The universal design and low back pressure levels simplify installation.
- **Improved Engine Performance:** Restores optimal diesel engine performance by reducing emissions.
- **Customization Options:** Polishing, etching, and custom designs are available to meet specific requirements.
- We are committed to meet No₂/No_x ratio is not higher as per regulatory body.
- **Euro VI Compliance:** Our system meets or exceeds the stringent Euro VI emission standards.
- **Wide Application:** Suitable for diesel power generation sets more than 1000 KW.

System Components:

- Air inlet port
- Air outlet
- Particulate control diagnostic system(PCD)
- Passive Regeneration system
- Diesel oxidation catalyst (DOC)
- Diesel particulate filter (DPF)
- Selective Catalyst Reduction(SCR)
- Sensors(Temperature and Pressure)

You can rely on US.....

- Installation of NABL Lab Tested Pollution Control Device (PCD)
- Compliance from CPCB as in certification
- Compliance from CAQM as in certification
- Compliance from State Pollution Control Board
- Providing support and assistance to all compliance related as per present laws for Pollution Control Device
- Legal compliance: Consent amendment as per CPCB & Hon'ble NGT.



Mission for
Clean Air starts with
EO Energy



M5, 2nd Flr , M-Block Mkt
Greater Kailash – Part 1
New Delhi 110048

+91 9810195391
raj@dekonixindia.com

www.dekonixindia.com

Pollution Control Device