

CERTIFICATE


TÜV NORD CERT GmbH
herewith declares that

Jiangsu Sunport Power Corp., Ltd.
No.20, Xishi Road, Xinwu District,
Wuxi City, Jiangsu Province, 214028
P.R. China

is authorized to provide the product mentioned below with the mark as illustrated:

Description of product (details see Annex 2):

Crystalline Silicon Terrestrial Photovoltaic (PV) Modules



Valid from: 2025-03-21

Valid until: 2030-03-20

Certification program:

P12-VA-01 Rev. 17 09.20

Certification fundamental(s):

IEC 61215-1:2021 / EN IEC 61215-1:2021;
IEC 61215-1-1:2021 / EN IEC 61215-1-1:2021;
IEC 61215-2:2021 / EN IEC 61215-2:2021;
IEC 61730-1:2023;
IEC 61730-2:2023.

Registered No.:

44 780 25 406749 - 078

Manufacturer and factory(-ies):

See Annex 1

Test Report No.:

492013694.001

File No.:

PVP10139/24P



TÜV NORD CERT GmbH
Certification Body
Consumer Products



Essen, 2025-03-21

Please also pay attention to the information stated overleaf.

Manufacturer and factory(-ies):

Manufacturer: **Jiangsu Sunport Power Corp., Ltd.**
No.20, Xishi Road, Xinwu District,
Wuxi City, Jiangsu Province, 214028, P.R. China

Factory 1: **Xuzhou Sunport Power Co., Ltd.**
No.1, Fumin Road, High-tech Industrial Development Zone
Pizhou, Jiangsu Province, P.R. China

Factory inspection report no.: 862010357.008

Factory 2: **Jiangsu Sunport Power Corp., Ltd.**
No.20, Xishi Road, Xinwu District,
Wuxi City, Jiangsu Province, 214028, P.R. China

Factory inspection report no.: 862010574.004

Remark:

Factory inspection is mandatory to be performed annually. Please refer to factory inspection report for detailed information.

Description of product(s):

Module types:	PV Modules with Half-cut 182mm TOPCon Solar Cells: 144 cells: SSTxxxAH7T (xxx=565-590, in steps of 5) 120 cells: SSTxxxAH6T (xxx=470-490, in steps of 5) 108 cells: SSTxxxAH5T (xxx=425-440, in steps of 5)
Maximum system voltage:	1500V
Maximum overcurrent protection rating:	25A
Electrical protection class:	Class II
Pollution degree:	1
98th percentile module operating temperature (T ₉₈)	70°C
Design load (positive / negative):	3600Pa / 1600Pa
Safety factors:	1.5
Fire safety class:	Class C according to UL790

Remark:

For detailed product information, please refer to CDF (Constructional Data Form) attached to test report with same file no.



TÜV NORD CERT GmbH
Certification Body
Consumer Products